



## Model FTI-10A

### Multi-Tank

### Engineering Specifications

### Automated Diesel Fuel Maintenance System

### 1-4 Diesel Fuel Tanks up to 30,000 Gallons each

#### 1. Description

- a. Diesel fuel storage tank shall be equipped with an **FM APPROVED**, and **NFPA EQUIPMENT COMPLIANT** automated fuel maintenance system.
- b. Filtration system shall remove particulates to 1 micron and water to 99.5% from stored diesel fuel.
- c. Fuel stabilizer shall be added to the diesel fuel in storage.
- d. Fuel biocide shall be added to the diesel fuel storage annually.
- e. **Includes: Modbus RTU, RS485 Serial Communications.**

#### 2. Pump / Motor Ratings

- a. Pump: 10 GPM, Rotary gear, mechanical seal, positive displacement, pressure relief valve.
- b. Motor: 3/4 HP, 1725 RPM, 115/208-240V AC @ 8.4 / 4.2 Amps, 1 Phase, 50/60Hz, TEFC.

#### 3. Filtration Process

- a. Stage 1: Strainer, 100 mesh (spin on filter)
- b. Stage 2: 10 micron, particulate removal (spin on filter)
- c. Stage 3: 3 micron particulate removal (spin on filter)
- d. Stage 4: Final filter, 1 micron particulate removal. (element type)
- e. Stage 5: Water coalescer and separator to 5 PPM. (element type)

#### 4. Filter Replacement Kit: FRK-10A-S (Kit includes filters listed below.) (Not included with system)

- a. FL-50-100M – Strainer, 100 mesh, spin-on, 2 ea.
- b. FL-70-10N – 10 micron, spin-on, 2 ea.
- c. FL-70-03N – 3 micron, spin-on, 2 ea.
- d. FL-FBO-60327 – 1 micron / water separator, 2 ea.

#### 5. Controller Specifications

- a. Control panel shall be UL 508.
- b. Siemens 1200 Series PLC, UL/CSA/CE/FM approvals.
- c. Siemens CB1241 RS485 Module (**Modbus Module included**)
- d. Motor contactor: 115/230V AC, 12 Amps, AC-3, UL/SA/CE approvals.
- e. Motor overload: 115/230V AC, adjustable range 4-20 Amps, UL/SA/CE approvals.
- f. Circuit breaker: 2 Pole, 15 Amps.
- g. Lockable disconnect switch: 115/230V AC, 32 Amps, UL/CE approvals.
- h. Multi-pole terminal block: 26 Amps, 18-12 AWG
- i. Siemens basic touch screen display.





- j. PLC shall monitor items 1-6
- k. Alarm conditions 1-6 shall be indicated by an audible horn.
- l. Visual alarm descriptions for items 1-6 shall be shown on the touch screen.
  - i. 5 Stages of filtration. (See section 3. Filtration Process)
  - ii. Leak detection.
  - iii. Water level sensor.
  - iv. Motor overload. (Motor/Pump issue)
  - v. System pressure. (Pressure switch gauge)
  - vi. Low flow: Loss of prime.
- m. Signal device (audible alarm):120/230V AC, Slow pulse, 80 to 95 Db.
- n. Controller shall be programmable to operate up to four separate diesel fuel storage tanks.
- o. Controller shall be capable of operation up to eight solenoid valves or eight electric actuated ball valves.
- p. Controller shall have one dry contact (normally open) for remote general alarm status.
- q. Controller shall be programmable to time delay the following 4 operations:
  - i. Turning on the fuel pump. (1-90 seconds)
  - ii. Auto pressure relief. Timed opening of solenoid valves or actuated ball valves. (5-90 sec)
  - iii. Alarm trip delay. (1-90 seconds)
  - iv. Low Flow alarm delay. (1-6 minutes, default is 3 minutes)
- r. **Optional:** Control panel strip heater shall be a 50-watt, thermostat controlled.

## 6. Enclosure

- a. Cabinet shall have 2 lift off removable doors.
- b. Cabinet shall be treated with "**Zinc Primer**" for corrosion resistance and "**Powder Coat**" finish.
- c. Cabinet shall be manufactured to "**NEMA 3R**" standards and designed for rack or wall mounting.
- d. Cabinet size: 48"W x 48"H x 16.5"D.
- e. Leak detection: Provided in cabinet.
- f. System weight: 500 Lbs.
- g. Cardinal Powder Coat PN: T075-WH34 Semi-Glass Vein White/Black

## 7. Voltage Options

- a. Choose one (115V AC, 1 Phase, 50/60Hz) (208-240V AC, 1 Phase, 50/60Hz)

## 8. Plumbing

- a. Supply line shall be installed at the sump, or low end of the fuel tank.
- b. Supply line shall be installed 1" from the bottom of the fuel tank, with foot valve.
- c. Return line to be installed at the opposite end of the fuel tank.
- d. Caution should be taken not to exceed the 15 feet lift capability to the fuel circulation pump.
- e. Should total suction lift exceed 15 feet, the circulation pump in the FTI cabinet shall be removed.
- f. Installer shall provide & install a submersible pump.
- g. Submersible pump voltage shall match the FTI control panel voltage as ordered.
- h. Submersible pump shall be wired to the FTI control panel.





- i. Flow control valve (included) and a flow meter (included) shall be installed in the FTI cabinet to adjust the flow to 10 GPM.
- j. Inlet Connection = 1.5" NPT.
- k. Outlet Connection = 1.5" NPT

**9. Installation Precautions:**

- a. If power to the FTI control panel is to be turned off after it is installed, then the installer shall provide for thermal expansion protection.
- b. All manual ball valves shall remain open. This will allow fuel thermal expansion to flow back to the fuel tank.
- c. The FTI control panel will automatically open all electronically connected valves when the FTI pressure switch gauge reaches 45 PSI. This will open and close all supply and return line valves connected to the FTI control panel 24/7, one tank at a time.
- d. This feature operates automatically only when power is on, and the control panel is set to "Auto Mode Off" or "Manual Mode Off"
- e. Installer should prevent any closed loop with the FTI-10A system in the middle.
- f. FTI will not be responsible for any damage due to excessive line pressure caused by thermal expansion.

**Model FTI-10A Multi-Tank System as Manufactured by  
Fuel Technologies International**

